

Extract : AS/NZS 3760:2003

This is an extract and must be read in conjunction with the entire Standard, in particular Clause 2.1

Licence # EC5503

Type of environment and / or equipment  (a)	Interval between inspection & tests						
	Class of equipment		Residual Current Device (RCDs)				Cord sets & power z  (h)
	Class I (Protectively Earthed)  (b)	Class II (Double Insulated)  (c)	Push-button test - by User		Operating time & push - button test		
			Portable (d)	Fixed (e)	Portable (f)	Fixed (g)	
1  Factories, workshops, places of work or repair, manufacturing, assembly, maintenance or fabrication	6 Months	12 Months	Daily, or before every use, which ever is longer	6 Months	12 Months	12 Months	6 Months
2  Environment where the equipment or supply flexible cord is subject to flexing in normal use OR is open to abuse OR is in a hostile environment	12 Months	12 Months	3 Months	6 Months	12 Months	12 Months	12 Months
3  Environment where the equipment or supply cord is NOT subject to flexing in normal use and is NOT open to abuse and is NOT in a hostile environment.	5 Years	5 Years	3 Months	6 Months	2 Years	2 Years	5 Years
4  Residential type areas of : Hotels, residential institutions, motels, boarding houses, halls, hostels, accommodation houses, and the like	2 Years	2 Years	6 Months	6 Months	2 Years	2 Years	2 Years
5  Equipment used for commercial cleaning	6 Months	12 Months	3 Months	N/A	12 Months	N/A	12 Months
6  Hire Equipment Inspection	Prior to Hire	Including push - button test by hirer prior to hire	N/A	N/A	Prior to Hire		
Test & Tag	3 Months	N/A	3 Months	12 Months	3 Months		

**Appendix G G5 Documentation**

Records of maintenance, including ( but not limited to) tests, should be kept throughout the working life of the equipment. Such records are a useful management tool for reviewing the frequency of inspection and test actions, and ensuring these actions have been carried out. It is recommended that such records be retained for not less than seven years.

**ENQUIRIES CALL**  
**BARRY LEE 0408 408 321**

